



May 18, 2026

Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Sarah Huckabee Sanders

Renee Mallory, RN, BSN Secretary of Health

Jennifer Dillaha, MD, Director

Public Health Engineering Branch, Slot 37
www.healthy.arkansas.gov/eng

Ph (501) 661-2623 Fax (501) 661-2032
After Hours Emergency (501) 661-2136

SCOTT BORMAN
BENTON-WASHINGTON REGIONAL PWA PWS # 871
15531 WOODS LODGE RD
ROGERS, AR 72756

RE: Organic Chemical Analysis, Laboratory Number(s)
O237830-MCP-1, O237830-QUA-1, O237830-CAR-1, O237830-EDB-1, O237830-VOC-1, O237830-END-1, O237830-GLY-1

Dear SCOTT BORMAN:

Attached are results of the above referenced laboratory analysis of the sample(s) collected from your public water system.

The finished water quality is within the allowable limits of the "Primary Drinking Water Standards" of the Safe Drinking Water Act.

Federal Law requires the water system to keep copies of the analysis reports for treated water for a minimum of ten years.

If you have any questions, please contact this office at 501-661-2623.

Sincerely,

Grayson Mixon
Environmental Health Specialist
Engineering Branch – ADH

DBG:GM:gm

Enclosures: Organic Lab Analysis

File: BENTON-WASHINGTON REGIONAL PWA 871



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: 0237830-GLY-1

Profile: GLY

Engineering Form ID:	237830		
Collected by:	Steven Fitzhugh	Received by:	Tyrone Shepard
Collected on:	04/07/2026 09:20	Received on:	04/09/2026 07:39
Public Water System:	BENTON-WASHINGTON REGIONAL PWA (871)	District:	1
Sampling Site:	Water Treatment Plant (871YE005)		
Type: EPT (Entry Point)	Purpose: CMP(Compliance)	Source: Lake	Category: PUB (Public/Community)

Glyphosate 547.0 Batch Run #: 5006 Date Analyzed: 04/13/2026

Regulated Analytes

Glyphosate < 2.5 ug/L

Approved by: BJ Jefferson Date Approved: 04/14/2026

Received Engineering

APR 16 2026

AR Dept. of Health



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: O237830-END-1

Profile: ENDO

Engineering Form ID: 237830

Collected by: Steven Fitzhugh

Received by: Tyrone Shepard

Collected on: 04/07/2026 09:20

Received on: 04/09/2026 07:39

Public Water System: BENTON-WASHINGTON REGIONAL PWA (871)

District: 1

Sampling Site: Water Treatment Plant (871YE005)

Type: EPT (Entry Point)

Purpose: CMP(Compliance)

Source: Lake

Category: PUB (Public/Community)

Endothall 548.1 Batch Run #: 5005 Date Analyzed: 04/14/2026

Regulated Analytes

Endothall

< 9.0 ug/L

Approved by: BJ Jefferson

Date Approved: 04/16/2026

Received Engineering
APR 23 2026
AR Dept. of Health



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: O237830-VOC-1

Profile: VOC

Engineering Form ID: 237830

Collected by: Steven Fitzhugh

Received by: Tyrone Shepard

Collected on: 04/07/2026 09:20

Received on: 04/09/2026 07:39

Public Water System: BENTON-WASHINGTON REGIONAL PWA (871)

District: 1

Sampling Site: Water Treatment Plant (871YE005)

Type: EPT (Entry Point)

Purpose: CMP(Compliance)

Source: Lake

Category: PUB (Public/Community)

Purgeable volatile organic compounds 524.2 Batch Run #: 4999 Date Analyzed: 04/14/2026

Regulated Analytes

Vinyl Chloride	< 0.50 ug/L
1,1-Dichloroethene	< 0.50 ug/L
Methylene Chloride	< 0.50 ug/L
t-1,2-Dichloroethene	< 0.50 ug/L
cis-1,2-Dichloroethene	< 0.50 ug/L
Carbon Tetrachloride	< 0.50 ug/L
Benzene	< 0.50 ug/L
Chlorobenzene	< 0.50 ug/L
1,2,4-Trichlorobenzene	< 0.50 ug/L
Tetrachloroethene	< 0.50 ug/L
1,2-Dichloroethane	< 0.50 ug/L
Trichloroethene	< 0.50 ug/L
1,2-Dichloropropane	< 0.50 ug/L
1,1,1-Trichloroethane	< 0.50 ug/L
1,1,2-Trichloroethane	< 0.50 ug/L
1,2-Dichlorobenzene	< 0.50 ug/L
Total Xylenes	< 0.50 ug/L
Toluene	< 0.50 ug/L
Ethylbenzene	< 0.50 ug/L
1,4-Dichlorobenzene	< 0.50 ug/L
Styrene	< 0.50 ug/L

Received Engineering
APR 23 2026
AR Dept. of Health

Approved by: BJ Jefferson

Date Approved: 04/16/2026



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: 0237830-EDB-1

Profile: EDB

Engineering Form ID: 237830

Collected by: Steven Fitzhugh

Received by: Tyrone Shepard

Collected on: 04/07/2026 09:20

Received on: 04/09/2026 07:39

Public Water System: BENTON-WASHINGTON REGIONAL PWA (871)

District: 1

Sampling Site: Water Treatment Plant (871YE005)

Type: EPT (Entry Point)

Purpose: CMP(Compliance)

Source: Lake

Category: PUB (Public/Community)

Ethylene dibromide/Dibromochloropropane 504.1 Batch Run #: 5025 Date Analyzed: 04/16/2026

Regulated Analytes

Ethylene dibromide < 0.02 ug/L

Dibromochloropropane < 0.02 ug/L

Approved by: BJ Jefferson

Date Approved: 04/21/2026

Received Engineering
APR 23 2026
AR Dept. of Health



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: 0237830-CAR-1

Profile: Carbs

Engineering Form ID: 237830
Collected by: Steven Fitzhugh Received by: Tyrone Shepard
Collected on: 04/07/2026 09:20 Received on: 04/09/2026 07:39

Public Water System: BENTON-WASHINGTON REGIONAL PWA (871) District: 1
Sampling Site: Water Treatment Plant (871YE005)
Type: EPT (Entry Point) Purpose: CMP(Compliance) Source: Lake Category: PUB (Public/Community)

Carbamates 531.2 Batch Run #: 4996 Date Analyzed: 04/15/2026

Regulated Analytes

Aldicarb Sulfoxide	< 0.2 ug/L
Aldicarb Sulfone	< 0.2 ug/L
Oxamyl	< 0.2 ug/L
Aldicarb	< 0.2 ug/L
Carbofuran	< 0.2 ug/L

Unregulated Analytes

Methomyl	< 0.2 ug/L
3-Hydroxycarbofuran	< 0.2 ug/L
Baygon	< 0.2 ug/L
Carbaryl	< 0.2 ug/L
Methiocarb	< 0.2 ug/L

Approved by: BJ Jefferson

Date Approved: 04/21/2026

Received Engineering
APR 23 2026
AR Dept. of Health



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: 0237830-QUA-1

Profile: QUAT

Engineering Form ID:	237830		
Collected by:	Steven Fitzhugh	Received by:	Tyrone Shepard
Collected on:	04/07/2026 09:20	Received on:	04/09/2026 07:39
Public Water System:	BENTON-WASHINGTON REGIONAL PWA (871)	District:	1
Sampling Site:	Water Treatment Plant (871YE005)		
Type: EPT (Entry Point)	Purpose: CMP(Compliance)	Source: Lake	Category: PUB (Public/Community)

Diquat/Paraquat 549.2 Batch Run #: 5001 Date Analyzed: 04/13/2026

Regulated Analytes

Diquat < 0.8 ug/L

Unregulated Analytes

Paraquat < 0.8 ug/L

Approved by: BJ Jefferson

Date Approved: 04/26/2026

Received Engineering
APR 30 2026
AR Dept. of Health



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: O237830-MCP-1

Profile: MCPAH

Engineering Form ID: 237830

Collected by: Steven Fitzhugh

Received by: Tyrone Shepard

Collected on: 04/07/2026 09:20

Received on: 04/09/2026 07:39

Public Water System: BENTON-WASHINGTON REGIONAL PWA (871)

District: 1

Sampling Site: Water Treatment Plant (871YE005)

Type: EPT (Entry Point)

Purpose: CMP(Compliance)

Source: Lake

Category: PUB (Public/Community)

Chlorinated Herbicides 515.4 Batch Run #: 4910 Date Analyzed: 04/18/2026

Regulated Analytes

Dalapon	< 2.2 ug/L
2,4-D	< 0.22 ug/L
Pentachlorophenol (PCP)	< 0.08 ug/L
2,4,5-TP (Silvex)	< 0.44 ug/L
Dinoseb	< 0.44 ug/L
Picloram	< 0.22 ug/L

Unregulated Analytes

2,4,5-T	< 0.22 ug/L
---------	-------------

Approved by: BJ Jefferson

Date Approved: 04/22/2026

Received Engineering

MAY 14 2026

AR Dept. of Health