



Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000
Governor Sarah Huckabee Sanders
Renee Mallory, RN, BSN, Secretary of Health
Jennifer Dillaha, MD, Director

Engineering Section, Slot 37 Ph (501) 661-2623 Fax (501) 661-2032
www.healthy.arkansas.gov/eng After Hours Emergency (501) 661-2136

Monday, October 20, 2025

SCOTT BORMAN PWS# 871
BENTON-WASHINGTON REGIONAL P
15531 WOODS LODGE RD
ROGERS AR 72756

RE: Unregulated Contaminant Monitoring Rule Results 5 (UCMR 5)

Lab No: O232978-533-1

Dear: SCOTT BORMAN

Attached are results of the above referenced laboratory analyses of the water sample(s) collected from your public water system.

If unregulated contaminants are detected above the minimum reporting levels (as cited at <http://water.epa.gov/lawsregs/rulesregs/sdwa/ucmr/ucmr4/methods.cfm>) then under the Consumer Confidence Report (CCR) Rule, 40 CFR 141.153(d), a Community Water System (CWS) must report the monitoring results.

The Public Notification Rule (40 CFR 141.207), published on May 4, 2000 (65 FR 25982) with amendments and corrections included in the Code of Federal Regulations for the Public Notification Rule published on July 1, 2006, requires PWSs to notify the public annually that the results of monitoring for unregulated contaminants are available. CCRs are to be sent to all billing customers each year by July 1. CWSs may include their public notice within their CCRs. Details on these reporting requirements can be found in the document: Revised Public notification Handbook (EPA 816-R-09-013), available on EPA's website at: <http://water.epa.gov/lawsregs/reulesregs/sdwa/publicnotification/upload/PNrevisedPNHandbookMarch2010.pdf>.

Federal Law requires the water system to keep copies of the analyses reports for treated water for a minimum of ten years. If you have any questions, please contact this office at 661-2623.

Sincerely,

Susan Corder, R.S.
Public Health Section Chief
Engineering Section



Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

FINAL REPORT

LIMS Sample Number: O232978-533-1

Profile: PFAS 533

Engineering Form ID: 232978
Collected by: Steven Fitzhugh Received by: Demond Williams
Collected on: 09/17/2025 09:05 Received on: 09/17/2025 14:05

Public Water System: BENTON-WASHINGTON REGIONAL PWA (871) District: 1
Sampling Site: Water Treatment Plant (871YC005)
Type: EPT (Entry Point) Purpose: INV(Investigative) Source: Lake Category: PUB (Public/Community)

PFAS 533 Batch Run #: 3837 Date Analyzed: 10/07/2025

Unregulated Analytes

PFHxS total	< 0.003 ug/L
PFOS total	< 0.002 ug/L
PFBA	< 0.005 ug/L
PFMPA	< 0.004 ug/L
PFPeA	< 0.003 ug/L
PFBS	< 0.003 ug/L
PFMBA	< 0.003 ug/L
PFEESA	< 0.003 ug/L
NFDHA	< 0.02 ug/L
PFHxA	< 0.003 ug/L
4:2FTS	< 0.003 ug/L
PFPeS	< 0.004 ug/L
HFPO-DA	< 0.005 ug/L
PFHpA	< 0.003 ug/L
ADONA	< 0.003 ug/L
6:2FTS	< 0.005 ug/L
PFOA	< 0.002 ug/L
PFHpS	< 0.003 ug/L
PFNA	< 0.004 ug/L
9CI-PF3ONS	< 0.002 ug/L
8:2FTS	< 0.005 ug/L
PFDA	< 0.003 ug/L
PFUnA	< 0.002 ug/L
11CI-PF3OUdS	< 0.005 ug/L
PFDaA	< 0.003 ug/L

Approved by: BJ Jefferson

Date Approved: 10/13/2025